



CO Alarms

Advice to users.

Testing

It is recommended that the alarm test function is operated monthly.

Alarm instructions

You should read the instruction information supplied by the alarm manufacturer.

Actions to be taken in the event of alarm activation

The accommodation unit should be vacated if the alarm sounds. You and your family should immediately vacate the home and should not re-enter until it has been proved safe to do so.

You should vacate the home even if the alarm has been quietened with any integral 'silence' button.

Isolate the gas or other fuel supply if it is possible to do so without re-entering the home.

Contact the Park Operator and advise that the alarm has been activated.

Maintenance

The alarm should only be cleaned with a vacuum or soft brush and no detergents should be used to clean the outer casing.

The sensor in the alarm has a maximum LIFE SPAN. You should therefore change the complete alarm after 7 YEARS from the date of manufacture. (This will usually be printed on a label on the alarm.) You should ensure that the replacement alarm complies with BSEN50291:2001 and that it is positioned in accordance with the manufacturer's installation instructions.

If the alarm 'low battery' warning signal is activated, then the alarm or battery (dependent upon the battery type) must be replaced. The method of indicating low battery power will be found in the individual alarm user information.



ABIHolidayHomes



Because the little things matter